



ABL ELECTRONIC SUPPLIES, INC.
1032-A CENTRAL DRIVE NW
CONCORD, NC 28027

PHONE/FAX: 704-784-4225/0255
SALES@ABLEWIRE-CABLE.COM
SALES@GROUNDSTRAPS.COM

NON-INSULATED RING TERMINALS- UL & CSA LISTED

24-20 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .047", MATERIAL: COPPER, .020" THICK

ADDITIONAL SPECIFICATIONS ARE AVAILABLE UPON REQUEST, ALL DIMENSIONS ARE NOMINAL AND SUBJECT TO CHANGE.

STUD

- #2 (.087" + .008")
- #4 (.126" + .008")
- #6 (.145" + .008")
- #8 (.169" + .008")
- #10 (.209" + .008")

NON-INSULATED RING TERMINALS- UL & CSA LISTED

22-16 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .067", MATERIAL: COPPER, .030" THICK

STUD

- #2 (.087" + .008")
- #4 (.126" + .008")
- #6 (.145" + .008")
- #8 (.169" + .008")
- #10 (.209" + .008")
- 1/4" (.252" + .016")
- 5/16" (.331" + .016")
- 3/8" (.413" + .016")



ABL ELECTRONIC SUPPLIES, INC.
1032-A CENTRAL DRIVE NW
CONCORD, NC 28027

PHONE/FAX: 704-784-4225/0255
SALES@ABLEWIRE-CABLE.COM
SALES@GROUNDSTRAPS.COM

NON-INSULATED RING TERMINALS- UL & CSA LISTED

16-14 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .090", MATERIAL: COPPER, .032" THICK

ADDITIONAL SPECIFICATIONS ARE AVAILABLE UPON REQUEST, ALL DIMENSIONS ARE NOMINAL AND SUBJECT TO CHANGE.

STUD

#2 (.087" + .008")
#4 (.126" + .008")
#6 (.145" + .008")
#8 (.169" + .008")
#10 (.209" + .008")
1/4" (.252" + .016")
5/16" (.331" + .016")
3/8" (.413" + .016")
1/2" (.512" + .016")

NON-INSULATED RING TERMINALS- UL & CSA LISTED

12-10 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .133", MATERIAL: COPPER, .037" THICK

STUD

#4 (.126" + .008")
#6 (.145" + .008")
#8 (.169" + .008")
#10 (.209" + .008")
1/4" (.252" + .016")
5/16" (.331" + .016")
3/8" (.413" + .016")
1/2" (.512" + .016")



ABL ELECTRONIC SUPPLIES, INC.
1032-A CENTRAL DRIVE NW
CONCORD, NC 28027

PHONE/FAX: 704-784-4225/0255

SALES@ABLEWIRE-CABLE.COM

SALES@GROUNDSTRAPS.COM

NON-INSULATED RING TERMINALS- UL & CSA LISTED

8 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .177", MATERIAL: COPPER, .046" THICK

ADDITIONAL SPECIFICATIONS ARE AVAILABLE UPON REQUEST, ALL DIMENSIONS ARE NOMINAL AND SUBJECT TO CHANGE.

STUD

#8 (.169" + .008")

#10 (.209" + .008")

1/4" (.252" + .016")

5/16" (.331" + .016")

3/8" (.413" + .016")

1/2" (.512" + .016")

NON-INSULATED RING TERMINALS- UL & CSA LISTED

6 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .228", MATERIAL: COPPER, .058" THICK

STUD

#10 (.209" + .008")

1/4" (.252" + .016")

5/16" (.331" + .016")

3/8" (.413" + .016")

1/2" (.512" + .016")

5/8" (.669" + .008")

3/4" (.826" + .008")



ABL ELECTRONIC SUPPLIES, INC.
1032-A CENTRAL DRIVE NW
CONCORD, NC 28027

PHONE/FAX: 704-784-4225/0255
SALES@ABLEWIRE-CABLE.COM
SALES@GROUNDSTRAPS.COM

NON-INSULATED RING TERMINALS- UL & CSA LISTED

4 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .303", MATERIAL: COPPER, .068" THICK

ADDITIONAL SPECIFICATIONS ARE AVAILABLE UPON REQUEST, ALL DIMENSIONS ARE NOMINAL AND SUBJECT TO CHANGE.

STUD

#10 (.209" + .008")
1/4" (.252" + .016")
5/16" (.331" + .016")
3/8" (.413" + .016")
1/2" (.512" + .016")
5/8" (.669" + .008")
3/4" (.826" + .008")

NON-INSULATED RING TERMINALS- UL & CSA LISTED

2 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .370", MATERIAL: COPPER, .072" THICK

STUD

#10 (.209" + .008")
1/4" (.252" + .016")
5/16" (.331" + .016")
3/8" (.413" + .016")
1/2" (.512" + .016")
9/16" (.590" + .016")
5/8" (.669" + .008")
3/4" (.826" + .008")



ABL ELECTRONIC SUPPLIES, INC.
1032-A CENTRAL DRIVE NW
CONCORD, NC 28027

PHONE/FAX: 704-784-4225/0255
SALES@ABLEWIRE-CABLE.COM
SALES@GROUNDSTRAPS.COM

NON-INSULATED RING TERMINALS- UL & CSA LISTED

1-0 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .448", MATERIAL: COPPER, .076" THICK

ADDITIONAL SPECIFICATIONS ARE AVAILABLE UPON REQUEST, ALL DIMENSIONS ARE NOMINAL AND SUBJECT TO CHANGE.

STUD

1/4" (.252" + .016")

5/16" (.331" + .016")

3/8" (.413" + .016")

1/2" (.512" + .016")

9/16" (.590" + .016")

5/8" (.669" + .008")

3/4" (.826" + .008")

NON-INSULATED RING TERMINALS- UL & CSA LISTED

2-0 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .523", MATERIAL: COPPER, .076" THICK

STUD

5/16" (.331" + .016")

3/8" (.413" + .016")

1/2" (.512" + .016")

9/16" (.590" + .016")

5/8" (.669" + .008")

3/4" (.826" + .008")



ABL ELECTRONIC SUPPLIES, INC.
1032-A CENTRAL DRIVE NW
CONCORD, NC 28027

PHONE/FAX: 704-784-4225/0255

SALES@ABLEWIRE-CABLE.COM

SALES@GROUNDSTRAPS.COM

NON-INSULATED RING TERMINALS- UL & CSA LISTED

3-0 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .570", MATERIAL: COPPER, .091" THICK

ADDITIONAL SPECIFICATIONS ARE AVAILABLE UPON REQUEST, ALL DIMENSIONS ARE NOMINAL AND SUBJECT TO CHANGE.

STUD

5/16" (.331" + .016")

3/8" (.413" + .016")

1/2" (.512" + .016")

9/16" (.590" + .016")

5/8" (.669" + .008")

3/4" (.826" + .008")

NON-INSULATED RING TERMINALS- UL & CSA LISTED

4-0 AWG BRAID/ WIRE

BARREL INSIDE DIA.: .645", MATERIAL: COPPER, .103" THICK

STUD

5/16" (.331" + .016")

3/8" (.413" + .016")

1/2" (.512" + .016")

9/16" (.590" + .016")

5/8" (.669" + .008")

3/4" (.826" + .008")